

## CONTACT ID EVENT CODES CLASSIFICATION

The Event codes have been grouped according to the type of event, as described below.

### Medical Alarms - 100

100 Medical	101 Pendant transmitter	102 Fail to report in
-------------	-------------------------	-----------------------

### Fire Alarms - 110

110 Fire alarm	111 Smoke	112 Combustion	113 Water Flow
114 Heat	115 Pull Station	116 Duct	117 Flame
118 Near alarm			

### Panic Alarms - 120

120 Panic alarm	121 Duress	122 Silent	123 Audible
-----------------	------------	------------	-------------

### Burglar Alarms - 130

130 Burglary	131 Perimeter	132 Interior	133 24 Hour
134 Entry/Exit	135 Day/Night	136 Outdoor	137 Tamper
138 Near alarm			

### General alarms

140 General alarm	141 Polling loop open	142 Polling loop short	143 Expansion module failure
144 Sensor tamper	145 Expansion module tamper		

### 24 Hour Non-Burglary - 150 and 160

150 24 Hour non-burg	151 Gas detected	152 Refrigeration	153 Loss of heat
154 Water leakage	155 Foil break	156 Day trouble	157 Low bottled gas level
158 High temp	159 Low temp	161 Loss of air flow	

### Fire supervisory - 200 and 210

200 Fire supervisory	201 Low water pressure	202 Low CO2	203 Gate valve sensor
204 Low water level	205 Pump activated	206 Pump failure	

### System Troubles - 300 and 310

300 System trouble	301 AC loss	302 Low system battery	303 RAM checksum bad
304 ROM checksum bad	305 System reset	306 Panel program changed	307 Self-test failure
308 System shutdown	309 Battery test failure	310 Ground fault	

### Sounder/Relay Troubles - 320

320 Sounder/relay	321 Bell 1	322 Bell 2	323 Alarm relay
324 Trouble relay	325 Reversing		

### System Peripheral Troubles - 330 and 340

330 System Peripheral	331 Polling loop open	332 Polling loop short	333 Exp. module failure
334 Repeater failure	335 Local printer paper out	336 Local printer failure	

**Communication Troubles - 350 and 360**

350 Communication	351 Telco 1 fault	352 Telco 2 fault	353 Long range radio
354 Fail to communicate	355 Loss of radio supervision	356 Loss of central polling	

**Protection Loop Troubles - 370**

370 Protection loop	371 Protection loop open	372 Protection loop short	373 Fire trouble
---------------------	--------------------------	---------------------------	------------------

**Sensor Troubles- 380**

380 Sensor trouble	381 Loss of super. - RF	382 Loss of super. - RPM	383 Sensor tamper
384 RF xmtr. low battery			

**Open/close - 400**

400 Open/Close	401 O/C by user	402 Group O/C	403 Automatic O/C
404 Late to O/C	405 Deferred O/C	406 Cancel	407 Remote arm/disarm
408 Quick Arm	409 Keypress O/C		

**Remote Access - 410**

411 Callback request made	412 Success download access	413 Unsuccessful access	414 System shutdown
415 Dialer shutdown			

**Access Control - 420**

421 Access denied	422 Access report by user
-------------------	---------------------------

**System Disables - 500 and 510****Sounder/Relay disables - 520**

520 Sounder/Relay disable	521 Bell 1 disable	522 Bell 2 disable	523 Alarm relay disable
524 Trouble relay disable	525 Reversing relay disable		

**System peripheral Disables - 530 and 540****Communication Disables - 550 and 560**

551 Dialer disabled	552 Radio xmitter disabled
---------------------	----------------------------

**Bypasses - 570**

570 Zone bypass	571 Fire bypass	572 24 Hour zone bypass	573 Burg. bypass
574 Group bypass			

**Test/Misc. - 600**

601 Manual trigger test	602 Periodic test report	603 Periodic RF Xmission	604 Fire test
605 Status report to follow	606 Listen-in to follow	607 Walk Test Mode	621 Event log reset
622 Event log 50% full	623 Event log 90% full	624 Event log overflow	625 Time/Date Reset
626 Time/Date inaccurate	627 Program mode Entry	628 Program mode Exit	631 Exception Schedule change